

## Lisa Koerkenmeier

---

**From:** Ronald Cottrell  
**Sent:** Monday, April 12, 2021 7:26 AM  
**To:** Lisa Koerkenmeier  
**Subject:** McGrath Elementary

Lisa,  
Thank you for having the review meeting last week. As discussed, I am concerned with the entrance into the Fire Lane as being too narrow. The architects rendering leaves no room for gate control or other access control into this area. Additionally, signage for this area is key so that no parking occurs and blocks this access.  
Thanks again.

Sincerely,  
**Ronnie Cottrell, Fire Chief**  
City of Brentwood | 8756 Eulalie Avenue, Brentwood, Missouri 63144  
314.963.8619 Direct | 314.962.3869 Fax | [www.brentwoodmo.org](http://www.brentwoodmo.org)

